

# Herrimann

## Chapter 1 **FIRE CODE**

### 4-1-1: FIRE CODE ADOPTED:

### 4-1-2: AMENDMENTS TO FIRE CODE:

### 4-1-3: STORAGE OF HAZARDOUS MATERIALS:

### 4-1-4: FEES:

### 4-1-5: CONTRACT FOR ADMINISTRATION AND ENFORCEMENT:

#### **4-1-1: FIRE CODE ADOPTED:**

- A. For the purpose of prescribing regulations governing conditions hazardous to life and property from fire and explosion, the 2009 edition of the international **fire code** ("IFC"), and any subsequent editions, including the international **fire code** standards, is hereby adopted, including appendices B, C, D, E, F, G, H, I, and J, but not appendix A thereof, with such amendments as are set forth below.
- B. Pursuant to Utah Code Annotated 10-3-711, a copy of the IFC has been filed in the office of the city recorder for use and examination by the public. (Ord. 10-25, 5-20-2010)

#### **4-1-2: AMENDMENTS TO FIRE CODE:**

- A. The city hereby adopts by reference and incorporates herein the amendments to the IFC, adopted by the Utah state legislature pursuant to Utah Code Annotated section 58-56-4 in house bill 308 (2010 general session).
- B. Section 903.4.2 of the IFC is amended to read as follows:

903.4.2 Alarms. Approved audible devices shall be connected to every automatic sprinkler system serving more than 20 fire sprinkler heads. Such sprinkler water flow alarm devices shall be activated by water flow equivalent to the flow of a single sprinkler of the smallest orifice size installed in the system. Alarm devices shall be provided on the exterior of the building and interior spaces per NFPA 72 in an approved location. With the exception of R-3 occupancies where a fire alarm system is installed, activation of the automatic sprinkler system shall activate the building fire alarm system.  
(Ord. 10-25, 5-20-2010)

#### **4-1-3: STORAGE OF HAZARDOUS MATERIALS:**

The storage of class I and class II hazardous materials in aboveground or belowground tanks, inside and outside of buildings is prohibited unless allowed by the zoning provisions applicable to the location in which the proposed tanks are to be located. In addition, the storage of class I and class II hazardous materials pursuant to this section is subject to the provisions of NFPA 30, 58 and 59A.  
(Ord. 10-25, 5-20-2010)

#### **4-1-4: FEES:**

In accordance with IFC, section 113, the city adopts the fees for hazardous materials permitting and inspection, fire inspection, fire watch, reinspection - delay in preparation at work site, and blasting permitting. All fees shall be collected by and paid to the unified fire authority at the time the permit, inspection, reinspection, or fire watch staffing is requested and shall be a condition for issuance of the permit and scheduling of the inspection, reinspection or fire watch staffing. (Ord. 10-25, 5-20-2010)

#### **4-1-5: CONTRACT FOR ADMINISTRATION AND ENFORCEMENT:**

The city contracts with the unified fire authority for **fire code** enforcement, administration and fire protection services. (2010 Code)