

Taylorsville

Chapter 9.40 **FIRE CODE**

9.40.010: ADOPTION OF CODE:

9.40.020: AMENDMENTS TO CODE:

9.40.030: STORAGE OF HAZARDOUS MATERIALS:

9.40.040: FEES:

9.40.010: ADOPTION OF CODE:

- A. For the purpose of prescribing regulations governing conditions hazardous to life and property from fire and explosion, the 2009 edition of the international **fire code** ("IFC"), and any subsequent editions, including the international **fire code** standards, is hereby adopted, including appendices B, C, D, E, F, G, H, I, and J, but not appendix A thereof, with such amendments as are set forth below.
- B. Pursuant to Utah Code Annotated 10-3-711, a copy of the IFC has been filed in the office of the city recorder for use and examination by the public. (Ord. 10-13, 5-19-2010)

9.40.020: AMENDMENTS TO CODE:

- A. The city hereby adopts by reference and incorporates herein the amendments to the IFC, adopted by the Utah state legislature pursuant to Utah Code Annotated section 58-56-4 in house bill 308 (2010 general session).
- B. Section 903.4.2 of the IFC is amended to read as follows:

903.4.2 Alarms. Approved audible devices shall be connected to every automatic sprinkler system serving more than 20 fire sprinkler heads. Such sprinkler water flow alarm devices shall be activated by water flow equivalent to the flow of a single sprinkler of the smallest orifice size installed in the system. Alarm devices shall be provided on the exterior of the building and interior spaces per NFPA 72 in an approved location. With the exception of R-3 occupancies where a fire alarm system is installed, activation of the automatic sprinkler system shall activate the building fire alarm system.
(Ord. 10-13, 5-19-2010)

9.40.030: STORAGE OF HAZARDOUS MATERIALS:

The storage of class I and class II hazardous materials in aboveground or belowground tanks, inside and outside of buildings is prohibited unless allowed by the zoning provisions applicable to the location in which the proposed tanks are to be located. In addition, the storage of class I and class II hazardous materials pursuant to this section is subject to the provisions of NFPA 30, 58 and 59A.
(Ord. 10-13, 5-19-2010)

9.40.040: FEES:

In accordance with IFC, section 113, the city adopts the fees for hazardous materials permitting and inspection, fire inspection, fire watch, reinspection - delay in preparation at work site, and blasting permitting as set forth below. All fees set forth below shall be collected by and paid to the unified fire authority at the time, the permit, inspection, reinspection, or fire watch staffing is requested and shall be a condition for issuance of the permit and scheduling of the inspection, reinspection or fire watch staffing.

FEE SCHEDULE

Material	Solid	Liquid	Gas	Fees UFA
Hazardous materials (annually)	≤500 lbs.	≤55 gal.	≤200 cu. ft. corrosive or oxidizer ≤504 cu. ft. oxygen	\$195.00 annually ¹
Hazardous materials (annually)	> 500 lbs.	> 55 gal.	> 200 cu. ft. corrosive or oxidizer > 504 cu. ft. oxygen	\$240.00 annually ¹
"H" occupancy backup generator (annually)				\$145.00 annually ²
"H" occupancy hazardous materials permit dispense and use (annually)		≤500 gal. tank	≤500 cu. ft.	\$195.00 annually ¹
"H" occupancy hazardous materials permit dispense and use (annually)		> 500 gal. tank	> 500 cu. ft., or any highly toxic gas	\$485.00 annually ¹
Other occupancy hazardous materials permit dispense and use (annually)		≥500 gal. tank	≥500 cu. ft.	\$195.00 annually ²
Aerosol products (annually)			> 500 lbs. level 2 or 3 aggregate qty.	\$195.00 annually ²
Flammable cryogenic		Indoors ≥1		\$195.00

fluid (annually)		gal., outdoors ≥60 gal.		annually ²
Aboveground tanks installation (flammable)			≤500 cu. ft. R-3 occupancy exempt	\$195.00 ¹ , \$75.00 per hour ²
Belowground tanks installation (flammable)			≤500 cu. ft. R-3 occupancy exempt	\$195.00 ¹ , \$75.00 per hour ²
Aboveground tanks installation (flammable)		> 500 gal.		\$395.00 ¹ , \$75.00 per hour ²
Belowground tanks installation (flammable)		> 500 gal.		\$395.00 ¹ , \$75.00 per hour ²
Pyroxylin plastics. Cellulose nitrate (pyroxylin) plastics (annually)	≥25 lbs.			\$195.00 (annually)
Body shop/garage under 5,000 sq. ft. (annually)				\$195.00 (annually)
Fireworks - outdoor public display (per event) cities, county exempt				\$485.00 (per event) ¹ , \$75.00 per hour per inspector ²
Open flame proximal audience indoor approved fireworks (per event)				\$195.00 (per event) ¹ , \$75.00 per hour ²
Application of flammable finishes, spray, or dip	More than 9 sq. ft. for flammable liquid spray application or ≥55 gal. for dip tank operations			\$195.00 ²
Blasting permit				\$75.00 per site, \$350.00 annually
Fire standby special events				\$75.00 per hour per fire

		inspector ²
Reinspection fee, delay in preparation at work site		\$75.00 first hour ² , \$150.00 every hour thereafter

Notes:

1. Fees are assessed separately.
2. Fees are assessed accumulatively (added to baseline permit fee).

Authorization by code:

IFC 105.1.1 Permits required, fees can be assessed.

IFC 105.1.2 Types of permits.

IFC 105.2.2 Inspection authorized.

IFC 113.1 Permit fees.

(Ord. 10-26, 8-4-2010)