

Utah State Fire Prevention Board Approved

Food Truck Fire Safety Check List

Date: _____ Truck Name: _____ Lic/VIN/Unit # _____

Owners Name: _____ Business Address: _____

Inspectors Name: _____ Fire Dept. _____ Phone # _____

Unless otherwise noted references are from Utah State adopted NFPA documents

LPG Containers and Piping

- LPG piping is code compliant
- Approved LPG containers [58:6.26.3]
- Containers installed outside or in vapor-tight cabinets accessible from outside [58:6.26.3.3]
- LPG containers mounted securely [58:6.26.3.4]
- Containers protected against impact [58:26.3.4.(E)]
- Protection of cylinder valve [58:6.26.3.4(G)]
- Shut off valve is readily accessible [58:6.26.4.1(3)]
- Flexibility between regulator and fixed piping [58:6.26.5.1(B)]
- LPG cylinders shall not be installed, transported, or stored inside the vehicle [58:6.26.3.2]
- No fueling or tank exchange during event or with public present [IFC 313.1.1]

LPG Appliances

- All appliances installed on vehicles shall be approved [58:6.26.7.2]
- Appliances shall be readily accessible [58:6.26.7.7]
- Appliances shall be protected to minimize damage in transit [58:6.26.7.8]
- Appliances shall not block egress [58:6.26.7.9]
- Install permanent caution plate [58:26.7.10]

Hood system

- Type 1 hood with grease laden vapors [96:4.1.9]
- Fire ext. system in hood with tag [96: Ch. 10]
- Proper ventilation and grease filters [96: Ch. 6 & 7]
- Hood cleaned at regular intervals [IFC 607.3.3.1]
- Ext. system serviced every 6 mo. [IFC 904.12.5.2]

Fire Extinguishers

- All cooking vehicles 2A10BC [58:6.26.1]
- K extinguisher if required [IFC 906.4.2]

Not in Service

- LPG system shall be leak free [58:6.26.8.2]
- Cylinders and/or containers shall be closed [58:6.26.9.3]
- Vehicle shall not be parked near heat sources, open flame, other ignition sources, or open pits. [58:6.26.8.4]

Access

- Fire apparatus access roads shall not be obstructed [IFC 503.4]

Electrical

- Electrical hazards shall be abated [IFC 604.1]
- Electrical panels shall be accessible [IFC 604.3] Be reasonable!
- Extension cords shall not replace permanent wiring [IFC 604.5] **Should expect exterior cords**
- No open junction boxes [IFC 604.6]
- Safe use of generators [IFC 313.1.1]

General Requirements

- No Smoking sign [IFC 310, 6107.2]
- No public in vehicle [R710-14-5(a)]
- Business license
- No fueling during event or with public present [IFC 313.1.1]
- LPG gas detector installed [R710-14-5(e)]

Comments: _____

Owner/Operator Signature: _____ Phone # _____

Approved: Y N Approval Date: _____ Correction and re-inspection required: Y N

[Type text]

09/18/2019