



Fire Inspection Services
Marijuana Facility Inspection Checklist



Type of Facility: Grow [] Production [] Extraction [] Combination []

Occupancy Classification: B [] M [] F-1 [] F-2 [] **Number of Exits required** _____

Type of Extractions: Butane [] Propane [] Heptane [] CO₂ [] Ethanol []
 Isopropanol [] Acetone [] Water / Non-Hazardous []

Extractor Model # _____ **Serial #** _____

Outside Items	Yes	No	N/A	Location
Address numbers / Visible from street				
Key Box (Knox or other)				
NFPA Placards (as required)				
Exits discharge to public way				
FDC Access				
FDC Readily Visible				
Fire Lane signage				

Sprinkler System / Detection System(s) - Fire / CO ₂	Yes	No	N/A	Location
System Required (F-1, over 12,000 sf)				
Sprinkler Inspection Current				
Wrench and Spare Heads Available				
Riser Room Readily Accessible (no storage)				
FACP Readily Accessible (no storage)				
Normal Condition – no faults, troubles, alarms				
Alarm System(s) inspection current				
18" clearance between storage and sprinkler heads				
Ceiling tiles missing				

Electrical	Yes	No	N/A	Location
Are Grow Lights Listed				
Open outlets, Junction-boxes, panels, wiring				

Electrical	Yes	No	N/A	Location
Extension Cords being used				
Other listed equipment (pumps, ovens, freezers, vacuums)				
All panels labeled and marked				
Spacer(s) in electrical panel				
Panel access unobstructed				
Power strips				
No spliced or frayed cords or wires				

Combustible Storage	Yes	No	N/A	Location
Blocking means of egress				
In electrical, mechanical, equipment rooms				
Orderly, stable, away from heat sources				
Outside – not within 10’ of lot lines				
Underneath stairs				

Exiting	Yes	No	N/A	Location
Bolt locks / Security bars				
Single motion egress				
Double keyed indicating lock on front door(s)				
‘This door to remain unlocked’ sign				
Emergency lighting				
Internally illuminated exit signs				
Security grille secured (no more than 50% of exits)				
Exit doors open easily				
Free of obstructions				

Extinguishers	Yes	No	N/A	Location
Minimum 2A:10BC				
Visible and readily accessible				
Current Inspection				
Properly mounted				
Within 75 feet				

Special Hazards	Yes	No	N/A	Location
CO ₂ (Carbon Dioxide)				
Hazard detectors / alarms				
Class 1/Division 1 or Class 1 Division 2 Room(s)				
Hoods, Suppression Systems				
Ventilation				

